




Innovation • Inspiration • Excellence for All

One Larkin Center
Yonkers, New York 10701
Tel. 914 376-8008
mpelliccio@yonkerspublicschools.org

MEMORANDUM

DATE: May 23, 2024
TO: Anibal Soler, Jr. 
FROM: Michael Pelliccio
RE: Request for Emergency Declaration
Lincoln High School Electrical Service - Feeder Replacement

Anibal Soler, Jr.
Superintendent of Schools

Michael Pelliccio
Executive Director of Facilities III
School Facilities Management


On May 9, 2024 Con-Edison informed the District that they had discovered one of the School's two main electrical service feeders had failed. Two feeders are provided, one as a primary and one as a secondary (backup), The failure of the primary feeder requires immediate replacement in order to ensure there is no prolonged loss of power to the Lincoln High School.

School Facilities Management Department will be utilizing Barile Gallagher Associate Engineers under their existing "On-Call" AE requirement contract to prepare bid documents in accordance with Con-Edison specifications. The District will solicit three (3) quotes to Electrical Contractors recommended by the district's engineer who specialize in high voltage work and will issue a Notice to Proceed to the lowest responsive bidder. The cost of this work is expected to be roughly \$75,000.00. We intend to perform this work under building repair funds.

Due to the time constraints and the length of time typically involved in the procurement of construction under GML 103 it is required that an Emergency Declaration be issued to expedite this work.

Please indicate your approval/disapproval of this Emergency Declaration by signing below:

APPROVED:

 5/24/24


Anibal Soler, Jr. Superintendent of Schools

DENIED:

Anibal Soler, Jr. Superintendent of Schools

MP/lp

cc: J. Liszewski, T. Collich, M. Martinez, L. Pavone, Brad Gorson, A. DiLello, R, Varillas




Innovation • Inspiration • Excellence for All

One Larkin Center
Yonkers, New York 10701
Tel. 914 376-8100
Fax 914 376-8584
asoler@yonkerspublicschools.org

Anibal Soler, Jr.
Superintendent of Schools

DATE: May 31, 2024

TO: Dr. Rosalba Corrado Del Vecchio, President,
Trustee Gail Burns, Vice President
& Members of the Board of Education

FROM: Anibal Soler, Jr. 

RE: Request for Emergency Declaration – Lincoln High School Electrical Service –
Feeder Replacement

I have approved a Request for Emergency Declaration for the Lincoln High School electrical services feeder replacement from the Executive Director of School Facilities Management on May 23, 2024.

On May 9th, Con Edison informed the District that they had discovered one of the School's two main electrical service feeders had failed. Two feeders are provided; one as primary, and one as a secondary/backup. The failure of the primary feeder requires immediate replacement in order to ensure that there is not prolonged loss of power at Lincoln High School.

Barile Gallagher Associate Engineers, under their existing "on-call" EA requirement contract, have been asked by the School Facilities Management Department to prepare bid documents in accordance with Con-Edison specifications. The District will solicit three quotes from electrical contractors recommended by the district's engineer, who specializes in high voltage work, and will issue a Notice to Proceed to the lowest responsive bidder.

The cost of the work is expected to be approximately \$75,000.00.

Due to time constraints, the scope of work and the length of time typically involved in the procurement of construction under General Municipal Law 103, requires that an Emergency Declaration be issued to expedite this work.

AS: nmr

cc: J. Becker, T. Collich, B. Gorson, C. Jarufe, J. Liszewski, L. Pavone, M. Pelliccio